



liftinstituut
SINCE 1933

TYPE EXAMINATION CERTIFICATE

Issued by Liftinstituut B.V.

Certificate no. : NL21-400-1002-064-16 Revision no.: -

Description of the product : Lift Control System for electric lifts

Trademark : Mikrolift

Type no. : ML25E

Name and address of the manufacturer : Mikrolift Mühendislik Asansör Elektronik
Bilgisayar Otom. Sist. San. ve Tic. Ltd. Şti.
Musalla Bağlari Mah. Şehit Ahmet Değleri Sok. No: 42/A,
Selçuklu / Konya - Turkey

Name and address of the certificate holder : Mikrolift Mühendislik Asansör Elektronik
Bilgisayar Otom. Sist. San. ve Tic. Ltd. Şti.
Musalla Bağlari Mah. Şehit Ahmet Değleri Sok. No: 42/A,
Selçuklu / Konya - Turkey

Certificate issued on the following requirements : EN81-1:1998 + A3:2009 art. 9.11.3, 9.11.9, 9.11.13, 14.1.1, 14.1.2.1.3, annex F.8 & H

Test laboratory : None

Date of type-examination : October 2020 – January 2021

Additional document with this certificate : Report belonging to the type examination certificate
no.: NL21-400-1002-064-16

Additional remarks : The printed circuit board is not subjected to the laboratory tests
according to annex F.6 of EN81-1 + A3

Key parameters for detecting UCM
Detection distance (variable) : "ML1-ML2" (variable)
Max. response time MLKR1 : 8.5 ms
Max. response time incl. contactors: 25 ms
Speed and distance travelled : to be calculated

Conclusion : The printed circuit board meets the requirements referred to in
this certificate taking into account any additional remarks
mentioned above.

Amsterdam

Date : 08-01-2021
Valid until : 08-01-2026

ing A.J. van Ommen
International Business
Manager

Certification decision by