



liftinstituut
SINCE 1933



EU-TYPE EXAMINATION CERTIFICATE

Issued by Liftinstituut B.V.
identification number Notified Body 0400,
commissioned by Decree no. 2018-0000125182

Certificate no. : NL16-400-1002-064-09 Revision no.: 5

Description of the product : Lift Controller for electric and hydraulic lifts

Trademark : Mikrolift

Type no. : ML40P Ver-2.1

Name and address of the manufacturer : Mikrolift Mühendislik Asansör Elektronik
Bilgisayar Otom. Sist. San. ve Tic. Ltd. Şti.
Musalla Bağlari Mah. Şehit Ahmet Değleri Sok. No: 42/A,
Selçuklu / Konya - Turkey

Name and address of the certificate holder : Mikrolift Mühendislik Asansör Elektronik
Bilgisayar Otom. Sist. San. ve Tic. Ltd. Şti.
Musalla Bağlari Mah. Şehit Ahmet Değleri Sok. No: 42/A,
Selçuklu / Konya - Turkey

Certificate issued on the following requirements : Lifts Directive 2014/33/EU

Certificate based on the following standard : Parts of: EN 81-20:2020, EN 81-50:2020

Test laboratory : None

Date of EU-type examination : November 2015 – February 2021

Additional document with this certificate : Report belonging to the EU-type examination certificate
no.: NL16-400-1002-064-09REV.5

Additional remarks : Key parameters for detecting UCM:
Detection distance : "ML1-ML2" (variable)
Max. response time detector : 8.5 ms
Total response time : 25 ms
Speed and distance travelled : to be calculated.
See chapter 2 and 5 of the report belonging to this EU-Type
examination certificate for additional conditions. This revision
replaces certificate NL16-400-1002-064-09REV.4 of 12-04-2018

Conclusion : The safety component meets the requirements of the Lifts
Directive 2014/33/EU taking into account any additional remarks
mentioned above.

Amsterdam

Date : 10-02-2021
Valid until : 10-02-2026

ing A.J. van Ommen
International Business
Manager

Certification decision by